

MURRAY RIX

33C VAUXHALL INDUSTRIAL ESTATE
GREG STREET, REDDISH, STOCKPORT SK5 7BR
TEL 0161 475 0870 FAX 0161 475 0871



TEST CERTIFICATE

PARTICLE SIZE DISTRIBUTION

BS EN 933-1 : 1997 (Washing & Sieving Method)


Determination of water content in accordance with BS EN 1097-5:2008

CLIENT	Booth Ventures Ltd
SITE	Ravenhead
JOB NUMBER	MRN 2576/9

SAMPLE LABEL	20mm Pipe Bedding	DATE SAMPLED	26-Sep-16
LAB SAMPLE No	67974	DATE RECEIVED	27-Sep-16
DATE TESTED	28-Sep-16	SAMPLED BY	Client

MATERIAL	20mm Pipe Bedding
ADVISED SOURCE	Ravenhead Quarry

Sieve Size (mm)	% Passing (%)	Specification (%)	Sieve Size (mm)	% Passing (%)	Specification (%)
125	100		6.3	4	
90	100		5	4	
80	100		4	3	
75	100		2	3	
63	100		1.18	3	
50	100		1	3	
40	100		0.6	3	
31.5	100		0.5	3	
28	100		0.425	3	
20	96		0.3	3	
16	57		0.25	3	
14	33		0.15	3	
10	7		0.125	3	
8	5		0.063	2.0	



REMARKS

As received moisture content = 3.9%

SIGNED

NAME

S.J. Hutchings
(Director)

DATE

04-Oct-16