

MURRAY RIX

33C VAUXHALL INDUSTRIAL ESTATE
GREG STREET, REDDISH, STOCKPORT SK5 7BR
TEL 0161 475 0870 FAX 0161 475 0871



TEST CERTIFICATE

PARTICLE SIZE DISTRIBUTION

BS EN 933-1 : 1997 (Washing & Sieving Method)


Determination of water content in accordance with BS EN 1097-5:2008

CLIENT	Booth Ventures Ltd
SITE	Ravenhead
JOB NUMBER	MRN 2576/9

SAMPLE LABEL	40mm Clean	DATE SAMPLED	26-Sep-16
LAB SAMPLE No	67975	DATE RECEIVED	27-Sep-16
DATE TESTED	28-Sep-16	SAMPLED BY	Client

MATERIAL	40mm Clean Stone
ADVISED SOURCE	Ravenhead Quarry

Sieve Size (mm)	% Passing (%)	Specification (%)	Sieve Size (mm)	% Passing (%)	Specification (%)
125	100		6.3	1	
90	100		5	1	
80	100		4	1	
75	100		2	1	
63	100		1.18	1	
50	100		1	1	
40	99		0.6	1	
31.5	94		0.5	1	
28	82		0.425	1	
20	22		0.3	1	
16	6		0.25	1	
14	4		0.15	1	
10	2		0.125	1	
8	1		0.063	0.7	



REMARKS

As received moisture content = 4.1%

SIGNED

NAME

S.J. Hutchings
(Director)

DATE

04-Oct-16