

MURRAY RIX

33C VAUXHALL INDUSTRIAL ESTATE
GREG STREET, REDDISH, STOCKPORT SK5 7BR
TEL 0161 475 0870 FAX 0161 475 0871



TEST CERTIFICATE PARTICLE SIZE DISTRIBUTION

BS EN 933-1 : 1997 (Washing & Sieving Method)


Determination of water content in accordance with BS EN 1097-5:2008

CLIENT	Booth Ventures Ltd
SITE	Ravenscroft
JOB NUMBER	MRN 2576/1

SAMPLE LABEL	6F5	DATE SAMPLED	Not advised
LAB SAMPLE No	65840	DATE RECEIVED	21-Mar-16
DATE TESTED	23-Mar-16	SAMPLED BY	Client

MATERIAL	6F5
ADVISED SOURCE	Ravenscroft

Sieve Size (mm)	% Passing (%)	Specification (%)	Sieve Size (mm)	% Passing (%)	Specification (%)
125	100	100	6.3	26	
90	100		5	24	
80	94	75-99	4	23	
75	89		2	18	0-35
63	69		1.18	16	
50	59		1	15	
40	51	50-90	0.6	14	
31.5	50		0.5	14	
28	47		0.425	13	
20	41	30-75	0.3	12	
16	37		0.25	12	
14	35		0.15	11	
10	31	15-60	0.125	10	
8	29		0.063	9.5	0-12



REMARKS

Sample complies with the advised grading specification 6F5 (SHW 2007)

As received moisture content = 4.4%

SIGNED

NAME

A. Richardson
(Laboratory Manager)

DATE

30-Mar-16